

CASTLE ROCK WATER

**RESOLUTION – CONSTRUCTION  
CONTRACT WITH GLOBAL  
UNDERGROUND CORP. FOR  
GLOVERS WATER REHAB PHASE 2  
PROJECT**

MARCH 1, 2022



# GLOVERS WATER REHABILITATION

## BACKGROUND

- Located in the Glovers neighborhood
- Distribution system was installed in 1976
- Existing pipes are undersized by current standards
- Significant number of breaks in recent years
- Phase 1 was completed in 2021



# GLOVERS WATER REHABILITATION

## SCOPE

- Project will be constructed in two phases
  - Phase 1 – Completed in 2021
  - Phase 2 – 2022
- Phase 2
  - 7,000 feet of 8” pipe
  - 13 fire hydrants
  - 23 gate valves
  - 1 check valve
  - 2,700 feet of sanitary laterals
  - Road reconstruction



Douglas Fir Ave.

# GLOVERS WATER REHABILITATION

## PROJECT SUMMARY

### Construction Contract

- Project was competitively bid
- Low bid – Global Underground
- Engineering Estimate = \$4,412,193
- Contract price = \$2,957,405.57
- 10% town managed contingency
- Total authorization of \$3,253,145.57

### Schedule

- Start – March 2022
- Complete – December 2022

### Recommendations

- Commission and Staff

FUND	AMOUNT	CONTINGENCY	TOTAL
WATER	\$ 1,957,830	\$ 195,783	\$ 2,153,613
SEWER	\$ 434,591	\$ 43,459	\$ 478,050
PUBLIC WORKS	\$ 564,985	\$ 56,498	\$ 621,483

# GLOVERS WATER REHABILITATION

## MOTION OPTIONS

- PROPOSED MOTION:

- *“I move to approve the Resolution as introduced by title.”*

- ALTERNATIVE MOTIONS:

- *“I move to approve the Resolution as introduced by title, with the following conditions: (list conditions).”*
- *“I move to continue this item to the Town Council meeting on \_\_\_\_ date to allow additional time to (list information needed).”*