

CASTLE ROCK WATER

RESOLUTION – CONSTRUCTION CONTRACT WITH 53 CORPORATION FOR THE TANK 3 DRAIN LINE PROJECT


FEBRUARY 2, 2021



TANK 3 DRAIN LINE PROJECT

BACKGROUND

- Located at Tank 3 on butte east of downtown.
- Tank was constructed in 1969.
- Overflows currently discharge to grade and flows towards Tacker Ct.
- New homes have been built on east side of Tacker Ct.



TANK 3 DRAIN LINE PROJECT

SCOPE

- Install new gravity drain line with discharge structure.
- Install new tank drain valve.
- Install new pressure relief valve.
- Installation of new tank maintenance by-pass main.



Tacker Court, down hill from Tank 3



Tank 3 Discharge

TANK 3 DRAIN LINE PROJECT

PROJECT SUMMARY

Construction Contract

- 53 Corporation
- Project was competitively bid
- Engineering Estimate = \$524,465
- Contract price = \$387,455
- 10% town managed contingency
- Total authorization of \$426,200

Schedule

- Start – February 2021
- Complete – May 2021

Recommendations

- Staff
- Castle Rock Water Commission



Looking along drain alignment from discharge location.



THANK YOU

QUESTIONS

RECOMMENDED MOTION: I MOVE TO APPROVE RESOLUTION NO. 2021-010
AS INTRODUCED BY TITLE.